




90 BEND




45 or 22.5 BEND




VERTICAL BEND




TEE or WYE




REDUCER



SEE NOTE 4



PLUGGED END



MINIMUM THRUST AREA BASED ON WATER PRESSURE OF — 1000KPa (150psi) & SOIL BEARING CAPACITY OF — 100KPa (2000psf)

FITTING	PIPE SIZE	AREA SQ. METRES	L x D AT FACE
90° BEND & HYDRANT 45° BEND	100	0.2	0.7 x 0.3m
	150	0.4	1.0 x 0.4m
	200	0.7	1.2 x 0.6m
	250	1.1	2.0 x 0.6m
	300	1.6	2.0 x 0.8m
	100	0.2	0.7 x 0.3m
	150	0.3	1.0 x 0.3m
	200	0.4	1.0 x 0.4m
or WYE	250	0.6	1.0 x 0.6m
	300	0.9	1.5 x 0.6m

- NOTES: 1. SOIL BEARING CAPACITY USED IS THAT FOR SOFT CLAY, FOR SOFTER SOILS THRUST BLOCKS SHALL BE DESIGNED BY THE ENGINEER.
 - 2. THRUST BLOCKING FOR FITTINGS LARGER THAN 300 \emptyset SHALL BE DESIGNED BY THE ENGINEER.
 - 3. VOLUME OF CONCRETE IN VERTICAL BEND ANCHORS TO BE DETERMINED BY THE ENGINEER. USE 2-20M RETAINING BARS PER CUBIC METRE.
 - 4. FOR CROSSES USE VALUE FOR 45' BEND IN EACH QUADRANT.

FITTING	PIPE SIZE	AREA SQ. METRES	L x D AT FACE
	100	0.1	0.5 x 0.2m
22.5°	150	0.2	0.7 x 0.3m
BEND	200	0.2	0.7 x 0.3m
BEIND	250	0.3	0.8 x 0.4m
	300	0.5	1.0 x 0.5m
	100	0.2	0.7 x 0.3m
CAPPED	150	0.3	0.8 x 0.4m
END OR TEE	200	0.5	1.0 x 0.5m
'	250	0.8	1.2 x 0.7m
	300	1.1	1.4 x 0.8m

- 5. WHERE PIPE SIZE DIFFERS IN ANY ONE FITTING USE VALUE FOR LARGEST SIZE.
- 6. CONCRETE NOT TO ENCROACH ON PIPE BARREL, BUT TO BEAR ON FITTING ONLY.
- 7. CONCRETE TO BE 20MPa (3000psi) COMPRESSIVE STRENGTH.
- 8. 6 mil POLY BETWEEN CONCRETE & FITTING.
- 9. ALL MEASUREMENTS ARE IN MILLIMETRES UNLESS NOTED.



CONCRETE THRUST BLOCK DETAILS

1	revision date:	scale:	_
ı	Sept. 2024		N.T.S.
ı	•		
ı			
ı			

standard drawing no.:

1.8