



NOTES:

1. METER TO BE INSTALLED BY CRD.
2. METER SETTERS TO BE FOR FLANGED METERS AND EQUIPPED WITH BYPASS, LOCKABLE INLET VALVE. LOCKABLE BYPASS VALVE, AND CHECK VALVE OUTLET, AS NOTED IN APPENDIX A APPROVED MATERIALS LIST.
3. FOR CONCRETE BRICKS PREAPPROVED IS BROWNSEY BLOCK – JUMBO BRICK (117mm x 92mm x 193mm)

ALL MEASUREMENTS ARE IN MILLIMETRES UNLESS NOTED