



NOTES:

- 1. HARD COPPER AND BRASS FITTINGS ONLY.
- 2. SHOW REMOTE METER READOUT LOCATION IN ELEVATION VIEW (EXTERIOR OF BUILDING). METER READOUT MUST BE EASILY ACCESSIBLE FOR METER READING. MINIMUM 1.2m /MAXIMUM 1.8 m FROM GROUND
- CONTRACTOR TO INSTALL WALL CONDUIT FOR METER CABLE.
- MINIMUM 10 PIPE DIAMETERS OF STRAIGHT PIPE BEFORE AND 5 PIPE DIAMETERS AFTER FLOW METER.
- 5. METER INSTALLATIONS 75mm Ø AND LARGER REQUIRE A STRAINER.
- BYPASS PIPE SIZE SHALL BE 1 PIPE SIZE SMALLER THAN THE PIPE TO THE METER. MAXIMUM BYPASS SIZE 50mm. SECURE AND STABILIZE.
- WATER METERS IN MECHANICAL ROOMS ARE ONLY PERMITTED IN APPROVED CASES.

- MINIMUM WORKING AREA WITH MINIMUM HEIGHT OF 2.0m
- A. SPECIFY SPACE FOR METER INSTALLATION.
- B. MINIMUM DISTANCE IN FRONT OF METER TO NEAREST PERMANENT OBSTRUCTION IS 920mm.
- C. SPECIFY HEIGHT. (MIN. 750mm, MAX 1500mm)
- D. SPECIFY VERTICAL DISTANCE FROM METER TO NEAREST PERMANENT OVERHEAD OBSTRUCTION. (MIN. 1220mm)

ALL MEASUREMENTS ARE IN MILLIMETRES UNLESS NOTED



WATER METER DETAIL MECHANICAL ROOM

revision date: Sept. 2024	scale:	N.T.S.
standard d	Irawing	no.:
3.4		