



Does your property have a storm drain?



Protecting Our Waters: Essentials for Saanich Peninsula Businesses

The Capital Regional District's Saanich Peninsula Stormwater Source Control Bylaw (Bylaw No. 4168) is designed to protect local waterways and marine shorelines.

Bylaw No. 4168 includes Codes of Practice for parking lots and outdoor storage operations, each with specific regulatory requirements. The key requirements involve maintaining stormwater rehabilitation units (SRUs) and having a spill response plan.

For tools and resources visit:

www.crd.bc.ca/bylaw4168



CRD

Making a difference...together

Requirements for Bylaw No. 4168

Stormwater Rehabilitation Unit (SRU*) Maintenance:

Inspect

- ☐ In parking lots **every 3 months**; and
- ☐ In storage areas **every 6 months**.

Clean


- ☐ When unit is 75% full either settled solids or floating oil and grease; and/or
- ☐ At least once a year *(or as specified by a maintenance plan)*.

Keep Records

- ☐ Of **inspections** *(including date and depths of settled solids, floating oil and debris); and*
- ☐ Of **cleaning and/or maintenance** *(including date and service provider)*.

Spill Response:

- ☐ Must have a Spill Response Plan and kit; and
- ☐ Store hazardous material in spill containment units.



*SRUs temporarily hold water, helping separate out solids, oil and grease. They include catch basins, oil separators, swales, and rain gardens.



For more information you can visit:

crd.bc.ca/bylaw4168

Contact us at: sourcecontrol@crd.bc.ca
or 250.360.3256

CRD
Making a difference...together